

Commonwealth of Virginia
Division of Consolidated Laboratory Services

600 North 5th St.
Richmond, Virginia 23219
804-648-4480



REPORT OF ANALYSIS

Report Date: 09/06/2024
DCLS LIMS #: E240804711

Mail To

WILDERNESS WATER TREATMENT PLANT
35249 WILDERNESS SHORES WAY
LOCUST GROVE, VA 22508

PWSID 7600023
REGION 7

ATTN: [REDACTED]

Sample Information

DATE RECEIVED	08/28/2024 10:24	LOCATION	WTP - RAW TAP
SAMPLING DATE	08/27/2024 16:55	FACILITY	IN001
COLLECTED BY	[REDACTED]	COMPLIANCE	N
SAMPLE MATRIX	DRINKING WATER	TYPE	SP
ORDERED TEST	206-104 M525	CATEGORY	GE
PROJECT NAME	DW2024-Q3	ORDER NUMBER	102575

Test Results

APPROVED BY: [REDACTED], Analyst Senior DATE APPROVED: 09/06/2024

<u>METHOD</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>PMCL</u>	<u>SMCL</u>	<u>ANALYSIS DATE</u>
<u>EPA 525.2</u>					
	Hexachlorocyclopentadiene	< 0.5 ppb	50		08/29/2024
	Hexachlorobenzene	< 0.1 ppb	1		08/29/2024
	Simazine	< 0.5 ppb	4		08/29/2024
	Atrazine	< 0.5 ppb	3		08/29/2024
	Lindane	< 0.1 ppb	0.2		08/29/2024
	Alachlor	< 0.2 ppb	2		08/29/2024
	Heptachlor	< 0.1 ppb	0.4		08/29/2024
	Heptachlor epoxide	< 0.1 ppb	0.2		08/29/2024
	Endrin	< 0.5 ppb	2		08/29/2024
	Bis (2-ethylhexyl) adipate	< 1 ppb	400		08/29/2024
	Methoxychlor	< 0.5 ppb	40		08/29/2024
	Bis (2-ethylhexyl) phthalate	< 2 ppb	6		08/29/2024
	Benzo(a)pyrene	< 0.11 ppb	0.2		08/29/2024
	Chlordane	< 0.2 ppb	2		08/29/2024
	Toxaphene	< 1 ppb	3		08/29/2024
	Polychlorinated biphenyls	< 0.3 ppb	0.5		08/29/2024

Explanation of Terms and Disclaimers

PMCL is defined as the "Primary Maximum Contaminant Level." SMCL is defined as the "Secondary Maximum Contaminant Level". If blank, level not defined by EPA. Results denoted with an asterisk (*) indicate that the PMCL is exceeded. Test Results meet requirements of NELAP. Non-NELAP accredited analyses noted by ^^. The results included on this report relate only to this specific sample and not to other samples tested from this sampling location.

CONFIDENTIALITY NOTICE: This report contains PRIVILEGED and CONFIDENTIAL INFORMATION. This report should not be reproduced, except in full, without the written approval of DCLS. If you have received this report in error, please notify DCLS immediately at (804) 648-4480 Ext. 171.